WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book

OFFICE USE ONLY
Log No. 40212
Permit No.
Basin 212

NOTICE OF INTENT NO. 10623

1. OWNER R.C. White Transportation
MAILING ADDRESS c/o Converse Consultants 4670 S. Polaris ave L.V.
ADDRESS AT WELL LOCATION R.C. White 4499 S. Arville St. Las Vegas, NV 89102

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 21 N (S) R 61 E Clark County
PERMIT NO. M0-2201 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.5	.5
Gravelly sand		.5	5	4.5
Caliche		5	8	3
Silty sand		8	11	3
Sandy silt		11	14.5	3.5
Silty sand		14.5	20	6.5
Sandy clay		20	25	5
Caliche		25	28	3
Silty sand		28	31	3
Sandy clay		31	36	5
Clayey sand		36	40	4

TD=40'

RECEIVED
NOV 20 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-20, 1992
Date completed 10-20, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)
8 Inches From 0 Feet To 40 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 15 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-13/11-13 Bent
Placement Method: ☑ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 13 feet to 40 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson (Contractor)
Address 4670 S. Polaris Ave (Contractor)
Las Vegas Nevada
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed Don Wilson
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627