WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40213
Permit No.
Basin 212

NOTICE OF INTENT NO. 10624

1. OWNER R.C. White Transportation
MAILING ADDRESS c/o Converse Consultants 4670 S. Polaris Ave L.V.
ADDRESS AT WELL LOCATION R.C. White Transp. 4499 S. Pruville St. Las Vegas, NV. 89102

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 21 N/S R. 61 E Clark County
PERMIT NO. M0-2201 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.5	.5
Gravelly sand		.5	4.5	4.
Caliche		4.5	7	2.5
Sandy silt trace gravel		7	9.5	2.5
Silty sand trace gravel		9.5	13	3.5
Sandy silt trace gravel		13	15	2.
Silty sand w/gravel		15	17.5	2.5
Sandy clay trace gravel		17.5	21	3.5
Silty sand trace gravel		21	24	3.
Sandy clay		24	27	3.
Clayey gravel		27	29.5	2.5
Caliche ~~Sandy gravel~~		29.5	32	2.5
Sandy gravel		32	34	2.
Sandy clay		34	40	6

T.D. = 40'

RECEIVED
NOV 20 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-20, 1992
Date completed 10-20, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
6	0	40

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.71 lbs	Sch. 40	0	33

Perforations:
Type perforation factory slotted
Size perforation 0.026
From 13 feet to 33 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-11 / Bent. 9-11
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/ Bent.
Gravel Packed: ☑ Yes ☐ No
From 9 feet to 40' feet

9. WATER LEVEL
Static water level 26. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas, Nevada.
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed (By driller performing actual drilling on site or contractor)
Date

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627