

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 40236
 Permit No. _____
 Basin 49

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10037

1. OWNER Charles Wilson ADDRESS AT WELL LOCATION 936 West Chance Rd. Bldg 1
 MAILING ADDRESS 936 West Chance Rd. Chance Rd. Apt 17

2. LOCATION NW 1/4 NW 1/4 Sec 12 T 34 N/S R 55 E ELKO County
 PERMIT NO. 32-001-17-4 West Chance Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	105	
Gravel	✓	105	110	
SANDSTONE		110	125	
Gravel	✓	125	130	
SANDSTONE		130	170	
Gravel	✓	170	172	
SANDSTONE CLAY		172	189	
Gravel	✓	189	200	

93 FEB 17 AIC:48 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>		<u>250</u>	<u>12</u>	<u>200</u>

Perforations:
 Type perforation slots
 Size perforation 3/8 - 3/4"
 From 170' feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 60

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 60 feet to 200 feet

9. WATER LEVEL
 Static water level 69 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor
 Address P.O. Box 525 Contractor
ELKO NV 89803

Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shouk Fertig
 By driller performing actual drilling on site or contractor
 Date 1-25-93

Date started NOV - 27 1993
 Date completed JAN - 10 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>45-50</u>		<u>6</u>