WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40062
Permit No.
Basin 87

NOTICE OF INTENT NO. 20096

1. OWNER Robert Madole
MAILING ADDRESS 210 Rhodes Rd
Reno, Nv 89511

ADDRESS AT WELL LOCATION 203 Rhodes Rd

2. LOCATION SW ¼ NW ¼ Sec. 33 T 18 N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 45-301-16 (Parcel No.) — Steamboat (Subdivision Name)

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	16	16
Multi-colored gravels with fine brown sand		16	70	54
Cobbles, multi-colored course sands & some fine brown sand		70	95	25
Multi-colored course gravels w/trace green clay		95	101	6
Multi-colored course gravels		101	109	8
Green clay w/ course multi-colored gravels		109	114	5
Multi-colored course gravels		114	138	24
T.D. 138 ft				

Date started 7/20/92, 19
Date completed 7/23/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Airlift	20+	100	1

8. WELL CONSTRUCTION
Depth Drilled 138 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
8 ½ Inches		50 Feet	138 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	138

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 122 feet to 132 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50
Placement Method: [XX] Pumped [ ] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date 7/27/92 Roger M. Thrall

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627