

OFFICE USE ONLY  
 Log No. 46246  
 Permit No. 87  
 Basin I

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21652

1. Consultant: Steffen Robertson and Kirsten Owner: Model Dairy  
 MAILING ADDRESS: 1755 E. Plumb Ln. Suite #241 ADDRESS AT WELL LOCATION: 500 Gould  
Reno, NV. 89502 Reno, NV.  
 2. LOCATION: SW 1/4 SW 1/4 Sec. 7 T. 19N N/S R. 20 E Washoe County  
 PERMIT NO. M/O - 492 Mill & Kietzke Area Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ABANDONMENT:				
Static Water Level	65			
Total Depth	75			
Equipment Used:				
- 75ft. 1"dia. Tremie pipe				
- High Pressure Cement pump & Mixer				
Materials Used:				
- 9 sacks of Portland Cement II				
- 2 bags Asphalt Patch				
1.) Measure SWL 65 & TD 75				
2.) Glue threaded adapter to existing casing				
3.) Set tremie pipe from bottom of casing.				
4.) Pump neat cement from bottom to surface.				
5.) Pull tremie, fill casing & attach from cement pump directly to casing.				
6.) Pump cement @100 to 125 PSI squeezing cement through perforations into the surrounding formation. When pressure increases, discontinue pumping.				
7.) Cut casing below grade & patch asphalt.				

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)

From To

Inches.....Feet.....Feet  
 Inches.....Feet.....Feet  
 Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation.....  
 Size perforation.....

From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal.....  
 Placement Method:  Pumped  Poured  
 Poured

Gravel Packed:  Yes  No  
 From.....feet to.....feet

Date started October 6, 1992, 19.....  
 Date completed October 6, 1992, 19.....

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level.....65.....feet below land surface  
 Artesian flow.....G.P.M.....P.S.I.  
 Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name.....WAYNE DRILLING INC. Contractor  
 Address.....P.O. Box 12370 Contractor  
RENO, NV. 89510 Contractor

Nevada contractor's license number 22549 issued by the State Contractor's Board.

Nevada driller's license number issued by the 908 Division of Water Resources the on-site driller.

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date February 10, 1993