this is a replacement well about 100' N of orig test well under log # 28702 RAD 3-29-99

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40269
Permit No.
Basin

NOTICE OF INTENT NO. 21180

1. OWNER Julian Smith
MAILING ADDRESS 8255 EAST LAKE BLVD CARSON CITY, NV 89710
ADDRESS AT WELL LOCATION 8255 EAST LAKE BLVD CARSON CITY, NV 89710

2. LOCATION SW ¼ SW ¼ Sec. 25 T. 16 N/S R. 19 E. WASHOE County
PERMIT NO. 50138 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT, SILT, CLAY, SMALL/LARGE GRAVEL SAND		0	3	3
BROWN SILT, FINE SAND		3	5	2
BROWN SANDS, SMALL GRAVELS		5	15	10
GRAY WHITE, LARGE SMALL SANDS		15	110	95
GRAY TO LIGHT BROWN SANDS		110	140	30
GRAY LARGE/SMALL SANDS		140	240	100
LIGHT BROWN LARGE SMALL SANDS		240	260	20

RECEIVED '93 FEB 18 AM 10:03 STATE ENGINEER'S OFF

Date started October 26, 1992
Date completed December 4, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250	177	12

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17½ Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	.250	0	260

Perforations:
Type perforation Johnson Hi-CAP
Size perforation .120 SLOT
From 0 feet to 100 feet Blank
From 100 feet to 180 feet Screen
From 180 feet to 190 feet Blank
From 190 feet to 210 feet Screen
From 210 feet to 230 feet Blank

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51
Placement Method: ☒ Pumped ☐ Poured
Seal Type: SEE ATTACHED SHEET. ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 51 feet to 260 feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION CO. (Contractor)
Address 9955 NORTH VIRGINIA ST (Contractor)
RENO, NV. 89506
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540
Signed (By driller performing actual drilling on site or contractor)
Date December 28, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

I

DATE:12-28-92

NOTICE OF INTENT NO: 21180

OWNER:JULIAN SMITH
8255 EAST LAKE BLVD
CARSON CITY, NV 89710

ADDRESS AT WELL LOCATION:8255
EAST LAKE BLVD
CARSON CITY, NV 89710

LOCATION: SW ¼ SW ¼ SEC 25 T 16 N R 19 WASHOE COUNTY
PERMIT NO:50138

ATTACHED SHEET FOR PERFORATION

FROM 230 FEET TO 250 FEET SCREEN
FROM 250 FEET TO 260 FEET BLANK

SARGENT IRRIGATION CO
9955 NORTH VIRGINIA ST
RENO, NEVADA 89506