

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 40273
 Permit No. _____
 Basin. 91

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21405

1. OWNER PARKIN MAY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 38 422 Hunkin Cir.
Truckee, CA 96160 Verdi, NV 89439
 2. LOCATION SW 1/4 NW 1/4 Sec 18 T. 19N N/S R 18 E Washoe County
 PERMIT NO. 38-083-11 Verdi area
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Top soil | | 0 | 1 | 1 |
| Volcanic boulder | | 1 | 5 | 4 |
| Boulders & gravel with brown clay | | 5 | 30 | 25 |
| Granite boulder | | 30 | 35 | 5 |
| XXXXXXXXXX Boulders & gravel w/brown clay | | 35 | 90 | 55 |
| Green clay | | 90 | 131 | 41 |
| Dark brown clay | | 131 | 190 | 59 |
| Gray clay | | 190 | 215 | 25 |
| Soft zone | X | 215 | 218 | 3 |
| Gray clay | | 218 | 222 | 4 |
| Dark brown clay | | 222 | 231 | 9 |
| Soft zone | X | 231 | 233 | 2 |
| Dark brown clay | | 233 | 250 | 17 |

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 100 Feet
8 5/8 Inches 100 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | | <u>.188</u> | <u>0</u> | <u>250</u> |

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 205 feet to 245 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 250 feet

9. WATER LEVEL
 Static water level 88 feet below land surface
 Artesian flow 23 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne C. Helman By driller performing actual drilling on site or contractor
 Date November 19, 1992

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 Date started 11-16-92, 19____
 Date completed 11-17-92, 19____

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |