WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40276
Permit No.
Basin 99

NOTICE OF INTENT NO. 10084

1. OWNER John Taylor
MAILING ADDRESS 670 Appaloosa Cir
ADDRESS AT WELL LOCATION 700 Appaloosa Cir Reno Nevada

2. LOCATION SE ¼ NE ¼ Sec. 5 T. 23 N/S R. 19 E/W Washoe County
PERMIT NO. (Issued by Water Resources) 078-291-05 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & decomposed gravel		0	300	

8. WELL CONSTRUCTION
Depth Drilled 302 Feet Depth Cased 302 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10¼	0	302

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	1.88	0	302

Perforations:
Type perforation Factory
Size perforation V8
From 262 feet to 302 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 302 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 59 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling (Contractor)
Address 2290 Pioneer Drive (Contractor)
Reno Nevada 89509
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476
Signed Steve McKay (By driller performing actual drilling on site or contractor)
Date 12/25/92

Date started 11/23/ 19 92
Date completed 11/30/ 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		7 HR

'93 JAN 32 P2:16
STATE ENGINEER'S OFFICE

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627