WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4027
Permit No.
Basin 09

NOTICE OF INTENT NO. 21747

1. OWNER Dan Kemp
MAILING ADDRESS 900 I St # 110
Sparks, Nv 89431

ADDRESS AT WELL LOCATION 22305 Red Rock Rd
Lot 80

2. LOCATION NW ¼ SE ¼ Sec 32 T 24 N/S R 18 E Washoe County
PERMIT NO. — Issued by Water Resources | 078-301-01 Parcel No. | — Red Rock Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt		0	1	1
Brown clay & little sands		1	65	64
Coarse volcanic sands		65	140	75
Coarse volcanic sands & little clay		140	151	11
T.D. 151 ft				

'93 FEB 23 AM 1:13 STATE ENGINEER'S OFFICE

Date started 11/16/92, 19
Date completed 11/18/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [XX] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10+		2½

8. WELL CONSTRUCTION
Depth Drilled 151 Feet Depth Cased 151 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	50
8	50	151

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	151

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 111 feet to 131 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [XX] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 151 feet

9. WATER LEVEL
Static water level flowing 1/4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 11/19/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627