

OFFICE USE ONLY  
 Log No. 40284  
 Permit No. \_\_\_\_\_  
 Basin 101-Parson Desert

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23620

1. OWNER Help-U-Sell Realty ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 710 W. Williams Avenue Lot #22 Woodlands Place  
Fallon, NV 89406 Fallon, NV 89406  
 2. LOCATION SE 1/4 SE 1/4 Sec. 6, T. 18 N. R. 29 E. Churchill County  
 PERMIT NO. Part of 6-732-07 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	11	11
Black Sand		11	12	1
Brown COarse Sand		12	15	3
Brown CLay		15	28	13
Black & Brown COarse & Fine Sand	X	28	33	5

8. WELL CONSTRUCTION  
 Depth Drilled 33 Feet Depth Cased 33 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 33 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	33

Perforations:  
 Type perforation Mill Cut  
 Size perforation 178"  
 From 29 feet to 32 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 25  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 25 feet to 33 feet

9. WATER LEVEL  
 Static water level 11 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

Date started January 2, 1993  
 Date completed January 2, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Dave Parsons  
 By driller performing actual drilling on site or contractor  
 Date Jan 29, 1993

93 FEB -3 10:56  
 STATE ENGINEERS OFFICE

93  
 93