


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ....

1. OWNER Arthur Bartholf ADDRESS AT WELL LOCATION 9021 Reno Hwy  
 MAILING ADDRESS P.O. Box 846 Fallon, NV 89406  
 2. LOCATION NE 1/4 SE 1/4 Sec 15 T. 19 N/S R. 27 E. Churchill County  
 PERMIT NO. 7-151-08 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	15	15
Brown Clay		15	32	17
Brown Coarse Sand		32	41	9
Brown Clay		41	43	2
Brown Coarse Sand		43	49	6
Brown Clay		49	51	2
Black & Green Coarse Sand		51	78	27
Fine Green Sand		78	84	6
Coarse Black & White Clay		84	95	11
Fine Gray Sand		95	97	2
Coarse Black & Green Sand		97	107	10
Fine Brown Sand		107	109	2
Fine Gray Sand		109	137	28
Coarse Gray Sand		137	153	16
Fine Gray Sand		153	158	5
Coarse Black & Green Sand		158	161	3
Fine Gray Sand		161	167	6
Brown Clay		167	173	6
Brown Coarse Sand		173	191	18

93 JAN 32 P 2:11 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 191 Feet Depth Cased 191 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 191 Feet  
12 Inches  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	191

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1 7/8"  
 From 186 feet to 194 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 191 feet

9. WATER LEVEL  
 Static water level 33' 4" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

Date started January 26, 1993  
 Date completed January 26, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc Contractor  
 Address P.O. BOX 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date Jan 27, 1993