

OFFICE USE ONLY
 Log No. 40289
 Permit No. _____
 Basin. 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23626

1. OWNER Pierson Construction ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 590 2686 Lenore Drive
Fallon, NV 89407 Fallon, NV 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 16 T. 19 N/S R. 29 E. Churchill County
 PERMIT NO. 7-391-42 CT & Ken A. Pierson
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Brown Clay		6	14	8
Fine Brown Sand		14	24	10
Fine & Coarse Brown Sand		24	31	7
Fine Brown Sand		31	35	4
Fine Green Sand		35	37	2
Black Sandy Clay		37	78	41
Fine Green Sand		78	82	4
Green & White Coarse Sand		82	89	7
Fine Green Sand		89	99	10
Brown Coarse Sand		99	111	12
Fine Brown Sand		111	128	17
Fine & Coarse Brown Sand		128	138	10

8. WELL CONSTRUCTION
 Depth Drilled 138 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 138 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	138

Perforations:
 Type perforation Mill Cut
 Size perforation 1 7/8"
 From 134 feet to 137 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 138 feet

9. WATER LEVEL
 Static water level 25' 5" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Doug Parsons
 By driller performing actual drilling on site or contractor
 Date Feb 15, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Date started February 8, 1993
 Date completed February 8, 1993

'93 FEB 18 AM 1:59
 RECEIVED
 STATE ENGINEERS OFFICE