

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 40297
 Permit No. 102
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2380

1. OWNER Guard L.T.D. ADDRESS AT WELL LOCATION 5285 CITRUS ST
 MAILING ADDRESS 3130 Villa Marbella Silver Springs Nv 89429
Circle Reno, Nv. 89509

2. LOCATION SW 1/4 SW 1/4 Sec 1 T 17 N/S R 24 E Lyon County
 PERMIT NO. 17-022-09 MOUNTAIN VIEW # 1
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Surface Soil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Fine to coarse Brown sand</u>		<u>3</u>	<u>10</u>	<u>7</u>
<u>Fine to coarse Brown sand & Brown clay</u>		<u>10</u>	<u>32</u>	<u>22</u>
<u>Brown clay</u>		<u>32</u>	<u>85</u>	<u>53</u>
<u>Firm coarse Brown Sand</u>	<u>X</u>	<u>85</u>	<u>141</u>	<u>56</u>

8. WELL CONSTRUCTION
 Depth Drilled 141 Feet Depth Cased 141 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 14 1/2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>141</u>

Perforations:
 Type perforation MILL
 Size perforation 3/32
 From 120 feet to 141 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 141 feet

9. WATER LEVEL
 Static water level 7.2 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 2-10 1993
 Date completed 2-11 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>2</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE Drilling & Development Contractor
 Address P.O. Box 668 Silver Springs Nv. 89429 Contractor

Nevada contractor's license number issued by the State Contractor's Board 14299
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726

Signed H. L. [Signature]
 By driller performing actual drilling on site or contractor
 Date 2-12-1993

'93 FEB 16 P12:18
 RECEIVED
 STATE ENGINEERS OFFICE