WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40298
Permit No.
Basin 102

NOTICE OF INTENT NO. 22302

1. OWNER Ben Perry
MAILING ADDRESS 4315 Deodar St. Silver Springs NV 89429
ADDRESS AT WELL LOCATION 4315 Deodar St. Silver Springs NV. 89429

2. LOCATION SW ¼ NE ¼ Sec. 36 T. 18 N/S R. 24 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) 18-515-06 (Parcel No.) Mountain View (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt and Sand		0	38'	38'
Light Brown Sticky Clay		38	85'	47'
Brown Clay And Course Sand		85'	102	17'
Brown Sticky Clay		102'	120'	18'
Fine To Medium To Course Sand.	✓	120'	137'	17'

93 FEB -5 P2:42 STATE ENGINEER'S OFFICE

Date started JAN 18 1993
Date completed JAN 27 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air developed for 6 Hrs		
Tested At 45 Gpm.		

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11"	Inches	0	Feet	60'	Feet
8 3/4	Inches	60	Feet	137'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	+1	137

Perforations:
Type perforation Air Perforator Star wheel
Size perforation 3/16 x 1" one inch apart
From ____ feet to ____ feet
From 5 Rows 120' feet to 137' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 80'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 80' feet to 137' feet

9. WATER LEVEL
Static water level 64' feet below land surface
Artesian flow NA G.P.M. 45 P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po. Box 599 Silver Springs NV. 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Jan 27 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627