

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 40304  
 Permit No. \_\_\_\_\_  
 Basin 105 I

NOTICE OF INTENT NO. 22215

1. OWNER Mel Owens ADDRESS AT WELL LOCATION 402 Chaine cct. Garcel, NV  
 MAILING ADDRESS 1307 Yellow Jacket Garcel, NV 89410  
 2. LOCATION NW 1/4 NW 1/4 Sec 23 T 12 N/S R 19 E Douglas County  
 PERMIT NO. 19-280-38 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name Foothill 20

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DG SANDSTONE</u>		<u>0</u>	<u>25</u>	
<u>SAND</u>		<u>25</u>	<u>35</u>	
<u>ROCKS</u>		<u>35</u>	<u>50</u>	
<u>SANDSTONE &amp; ROCKS</u>		<u>50</u>	<u>75</u>	
<u>ROCK</u>		<u>75</u>	<u>105</u>	
<u>SANDSTONE &amp; ROCKS</u>		<u>105</u>	<u>145</u>	
<u>SANDSTONE</u>		<u>145</u>	<u>200</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 200  
9 7/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.5 lbs</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation Factory Feet  
 Size perforation 2 X 5/32"  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From 200 feet to 50 feet

9. WATER LEVEL  
 Static water level 78 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Krauchack Drilling Inc Contractor  
 Address 2668 Fuller Windsor NV 89423 Contractor  
 Nevada contractor's license number #021268 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #7495  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 12-11-92

Date started 12-3 1992  
 Date completed 12-10 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>23+</u>	<u>-</u>	<u>3 hrs</u>

'93 FEB -3 P 2:20  
 RECEIVED  
 STATE ENGINEERS OFFICE