

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22218

1. OWNER Bruce Davis ADDRESS AT WELL LOCATION 1652 Samwise Ad.  
 MAILING ADDRESS 1652 Samwise  
Minden, NV 89423  
 2. LOCATION SW 1/4 SW 1/4 Sec. 1 T. 13 N/S R. 20 E. Douglas County  
 PERMIT NO. 23-090-40 Parcel No. \_\_\_\_\_ Subdivision Name Johnson 12  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & SAND		0	13	
SAND		15	25	
SAND & GRAVEL		25	35	
GRAVEL		35	40	
SAND		40	85	
SAND & GRAVEL		85	95	
SAND		95	110	
SAND & CLAY		110	145	
CLAY SAND & GRAVEL		145	150	
SAND & GRAVEL		150	170	

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 170 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>125 lbs.</u>	<u>1/8</u>	<u>0</u>	<u>170</u>

Perforations:  
 Type perforation Factory Port  
 Size perforation 3" x 5/32"  
 From 150 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 170 feet to 50 feet

9. WATER LEVEL  
 Static water level 81 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lawchack Drilling Inc. Contractor  
 Address 2668 Felter Minden Nv. Contractor

Nevada contractor's license number issued by the State Contractor's Board \*021268  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller \*1495  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 12-16-82

Date started 12-11 1982  
 Date completed 12-15 1982

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>304</u>		<u>2.5 hrs</u>