

OFFICE USE ONLY  
 Log No. 40311  
 Permit No. \_\_\_\_\_  
 Basin. 8-105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20832

1. OWNER DAVE FURIN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2824 Jersey Ln 2533 Fremont  
Minden NV Minden NV  
 2. LOCATION SE 1/4 NW 1/4 Sec. 2 T. 13 N/S R. 20 Douglas County  
 PERMIT NO. 23-510-03 Subdivision Name Johnson  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & CLAY		0	20	
GRAVEL		20	30	
SAND		30	55	
GRAVEL & ROCK		55	65	
SAND		65	100	
SAND & GRAVEL		100	105	
SAND & SILTS		105	120	
SAND CLAY & GRAVEL		120	180	
SAND & CLAY		180	205	

8. WELL CONSTRUCTION  
 Depth Drilled 205 Feet Depth Cased 203 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 205 Feet  
9 7/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>125 lbs</u>	<u>.188</u>	<u>0</u>	<u>203</u>

Perforations:  
 Type perforation Stake Perforation  
 Size perforation 3" x 15/32"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 180 feet to 203 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 203 feet to 50 feet

9. WATER LEVEL  
 Static water level 101 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Karchack Drilling Inc. Contractor  
 Address 2668 Elmer Minden NV Contractor  
 \_\_\_\_\_  
 Nevada contractor's license number issued by the State Contractor's Board 89423  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 221268  
4495  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 1-9-93

Date started 1-6 1993  
 Date completed 1-8 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>307</u>	<u>-</u>	<u>2 hrs</u>

'93 FEB 17 AM 0:23  
 STATE ENGINEERS OFFICE