

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20831

1. OWNER Dick Wheaton ADDRESS AT WELL LOCATION 3647 HWY 395
 MAILING ADDRESS PO Box 2153 C.C. NY
GAID NO 89410
 2. LOCATION SE 1/4 SE 1/4 Sec 6 T 14 N/S R 20 E Douglas County
 PERMIT NO. 10-040-62 Subdivision Name N/A
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>06 SAND & CLAY</u>		<u>0</u>	<u>60</u>	
<u>SAND & GRAVEL</u>		<u>60</u>	<u>75</u>	
<u>FINE SAND & CLAYS</u>		<u>75</u>	<u>180</u>	
<u>SAND (COARSE)</u>	<u>1st X</u>	<u>180</u>	<u>230</u>	
<u>SAND & SANDSTONE</u>	<u>2nd X</u>	<u>230</u>	<u>260</u>	
<u>SAND</u>	<u>2nd X</u>	<u>260</u>	<u>280</u>	
<u>SAND STONE</u>	<u>2nd X</u>	<u>280</u>	<u>330</u>	
<u>SAND</u>	<u>2nd X</u>	<u>330</u>	<u>350</u>	
<u>SANDSTONE</u>	<u>2nd X</u>	<u>350</u>	<u>360</u>	

5" liner placed from 220' to 360'

'93 FEB 17 AND '22
 STATE ENGINEERS OF ILL.

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 360 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet
360 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.5165</u>	<u>.188</u>	<u>0</u>	<u>240</u>
<u>5 9/16</u>	<u>-</u>	<u>.188</u>	<u>220</u>	<u>360</u>

Perforations:
 Type perforation Factory cut & hand cut
 Size perforation 3" X 5/32"
 From FC feet to 220 feet
 From HC feet to 240 feet
 From 300 feet to 320 feet
 From 340 feet to 360 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From Apex 180 feet to 50 feet

9. WATER LEVEL
 Static water level 190 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1-29, 1993
 Date completed 2-8, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>BAILER</u>	<u>12</u>	<u>10-15 FT</u>	<u>3 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kauchack Drilling Inc. Contractor
 Address 2668 Fuller Minden Wv Contractor
 Nevada contractor's license number issued by the State Contractor's Board #021268
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
 Signed Michael Allen
 By driller performing actual drilling on site or contractor
 Date 2-11-92