WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 40318
Permit No.
Basin 108

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 19836

1. OWNER Arimetco International, Inc.
MAILING ADDRESS 102 Burch
Yerington, Nevada 89447

ADDRESS AT WELL LOCATION 2 Miles North of Yerington

2. LOCATION SW ¼ SW ¼ Sec. 5 T. 13 N/S R. 25 E. Lyon County
PERMIT NO. M/O 547A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Monitor
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Alluvium & Rhyocite | | 0 | | |
| Volcanics | | | 55 | 55 |
| Water Seams | | 55 | 56 | 1 |
| Alluvium & Rhyocite | | 56 | | |
| Volcanics | | | 80 | 24 |

'93 JAN 32 P2:20
STATE ENGINEER'S OFFICE

Date started December 13, 19 92
Date completed December 13, 19 92

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

~~BAILER TEST~~ Air Test
G.P.M. 10 Draw down 25 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 80 feet
inches
inches
Casing record 4" PVC 0 - 80
Weight per foot Thickness

| Diameter | From | To |
|---|---|---|
| 4 inches | 0 feet | 80 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 20 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 20 feet to 80 feet

Perforations:
Type perforation Skillsaw
Size perforation 3/16" x 2½"
From 65 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 55 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue, Ely, NV 89301 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada contractor's driller's number issued by the Division of Water Resources 641
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed [signature] (By driller performing actual drilling on site or contractor)
Date January 26, 1993

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627