WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40331
Permit No.
Basin 137B

NOTICE OF INTENT NO. 22313

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain Nv 89045

ADDRESS AT WELL LOCATION
No physical address
Dedicated South Pad DMW #1

2. LOCATION NE ¼ SE ¼ Sec. 35 T. 10 N/S R. 43 E. Nye County

PERMIT NO. M0 1630 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sd, gravel - Boulders		0	40	40
Alluvium		40	270	230
greenish gravel - Round	✓	270	285	15
sd + gravel		285	310	25

'93 FEB 19 A11:22
STATE ENGINEER'S OFFICE

Date started 1-12, 1993
Date completed 1-16, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		4 hrs.

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 3/4 Inches	0 Feet	50 Feet
8 3/4 Inches	50 Feet	310 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	.250	+1	50
6 5/8	13.99	.204	+2	310

Perforations:
Type perforation Johnson Stainless steel
Size perforation .070
From [redacted] feet to [redacted] feet
From 270 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 285 feet to 305 feet

9. WATER LEVEL
Static water level 270 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature 134 °F Quality No Results from Test

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Waytek Drilling Co (Contractor)
Address 2220 Stowe Dr (Contractor)
Reno Nv 89511
Nevada contractor's license number issued by the State Contractor's Board 024521
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Leo Waytek (By driller performing actual drilling on site or contractor)
Date 1-22-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627