

OFFICE USE ONLY
 Log No. 40333
 Permit No. _____
 Basin. 137B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22315

1. OWNER Round Mountain Gold Corp ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 480 No physical Address
Round Mountain, Nv. 89045 dedicated South Pad DMW#3
 2. LOCATION SE 1/4 SE 1/4 Sec. 36 T. 10 N R. 43 E Alg Co. County
 PERMIT NO. MO 630 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Granite Wash		0	150	150
Granite Wash w/ Bk		150	480	330
Shale + Volcanics		480	630	150
Black shale		630	635	5
Granite				
Water strata at contact point (4' void) Shale + granite				

93 FEB 19 AM 122
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 630 Feet Depth Cased 630 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
14 3/4 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 630 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/4</u>	<u>28.04</u>	<u>0.250</u>	<u>+1</u>	<u>50</u>
<u>6 5/8</u>	<u>13.99</u>	<u>0.204</u>	<u>+2</u>	<u>590</u>

Perforations:
 Type perforation Johnson Stainless Steel
 Size perforation 1.070
 From 590 feet to 630 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 430 feet to 630 feet

9. WATER LEVEL
 Static water level 440 feet below land surface
 Artesian flow 2.5 G.P.M. _____ P.S.I.
 Water temperature 92 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Waytek Drilling Co. Contractor
 Address 2220 Stowe Dr Contractor
 Reno, Nv. 89511
 Nevada contractor's license number issued by the State Contractor's Board 24521
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Les Waytek
 By driller performing actual drilling on site or contractor
 Date 2-17-93

Date started 1-26, 1993
 Date completed 2-7, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>0</u>	<u>4 hrs</u>