

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

19 Book

OFFICE USE ONLY

Log No. **40371**

Permit No. **212**

Basin **212**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **11568**

1. OWNER **HARDING LAWSON ASSOCIATES** ADDRESS AT WELL LOCATION **4401 W. SAHARA CV. NO.**  
 MAILING ADDRESS **2300 PASADENA DR. P.O. BOX A-212 LAS VEGAS, NV. 89102**

2. LOCATION **N 2 1/4 N.W. 1/4 Sec 7 T 21 N. R 61 E CLARK** County  
 PERMIT NO. **MO-2233** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **UGER**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clays		0	10	
Clays w/ CEMENTED CALICHE		10	12	
Clays w/ some FINE SANDS	X	12	25	

8. WELL CONSTRUCTION  
 Depth Drilled **25** Feet Depth Cased **10** Feet

HOLE DIAMETER (BIT SIZE)  
 From **10** Inches To **0** Feet **25** Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>4.5</b>		<b>5/16</b>	<b>0</b>	<b>10</b>

Perforations:  
 Type perforation **SLOTTED SCREEN**  
 Size perforation **.020**  
 From **10** feet to **25** feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal **8**

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From **8** feet to **25** feet

**RECEIVED**  
**MAR 02 1993**  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. **14** WATER LEVEL  
 Static water level **14** feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature °F Quality

Date started **2-2** 19**93**  
 Date completed **2-2** 19**93**

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **WEBER ENVIRONMENTAL** Contractor  
 Address **4301 S. VALLEY VIEW** Contractor  
**LAS VEGAS NV. 89103**

Nevada contractor's license number issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M-1487**

Signed **[Signature]**  
 By driller performing actual drilling on site or contractor

Date **2-25-93**

