Corrected Copy

CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log Book No. 40390
Permit No. 55236
Basin

NOTICE OF INTENT NO. 10686

1. OWNER Sharon Voller
MAILING ADDRESS 999 W. Main Rd.
Middletown Rhode Island 02840

ADDRESS AT WELL LOCATION N/A

2. LOCATION ~~NW~~ NE NW ¼ Sec. 22 T. 22 N/S R. 60 E. Clark County
PERMIT NO. 55236 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	22	
Cemented Gravel		22	30	
Gravel		30	150	
Cemented Gravel		150	160	
Clay & Gravel		160	340	
Boulders		340	415	
Clay & Gravel		415	590	
Gravel & Water	X	590	650	

RECEIVED
OCT 11 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started December 19, 1992, 19
Date completed December 29, 1992, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 650 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
12 1/4"	0 Feet	55 Feet
9 7/8"	55 Feet	650 Feet
	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+1	650

Perforations:
Type perforation Factory
Size perforation 3/16" X 8 row
From 610 feet to 630 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 500 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F. Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Address 3035 S. Torrey Pines St. (Contractor)
Las Vegas, Nevada 89102 (Contractor)
Nevada contractor's license number 10062 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 12-30-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (D)-627