

40398  
 OFFICE USE ONLY  
 Log No. 40398  
 Permit No. 212  
 Basin 212  


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10692

1. OWNER Robert E. Georke ADDRESS AT WELL LOCATION N/A  
 MAILING ADDRESS 2117 W. Oakey Blvd.  
Las Vegas, Nev. 89102  
 2. LOCATION SW 1/4 SW 1/4 Sec. 7 T. 22 N/S R. 61 E. Clark County  
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New-Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & Clay		0	18	
Cemented Gravel		18	39	
Clay & Gravel		39	160	
Boulders		160	190	
Gravel & Clay		190	330	
Gravel & Water	xx	330	350	
Clay Gravel		350	400	
Gravel & Water	xx	400	415	
Cemented Gravel		415	480	
Gravel & Water	xx	480	495	

8. WELL CONSTRUCTION  
 Depth Drilled 495 Feet Depth Cased 495 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
 12 1/4" Inches 0 Feet 55 Feet  
 10 5/8" Inches 55 Feet 495 Feet  
 Casing Schedule  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+1	495

 Perforations:  
 Type perforation Factory  
 Size perforation 3/16 x 8 row  
 From 455 feet to 475 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 FEB 26 1993  
 Div. of Water Resources  
 Branch Office Las Vegas, NV

Date started 2/15/93 19\_\_\_\_  
 Date completed 2/22/93 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 295 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon H. Dimick Contractor  
 Address 3035 S Torrey Pines  
Las Vegas, Nevada 89102  
 Nevada contractor's license number issued by the State Contractor's Board 10062  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552  
 Signed V. H. Dimick  
 By driller performing actual drilling on site or contractor  
 Date 2-22-93

