WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40417
Permit No.
Basin 162

NOTICE OF INTENT NO. 11581

1. OWNER Larry Metler
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 28 T. 19S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 29-892-09 (Parcel No.) Bellvista unit 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	14	14
Caliche		14	16	2
Clay		16	38	22
Caliche		38	40	2
Clay		40	61	21
Caliche		61	63	2
Clay		63	76	13
Caliche		76	78	2
Clay		78	85	7
Caliche	WB	85	87	2
Clay		87	103	16
Caliche	WB	103	105	2
Clay		105	118	13
Caliche	WB	118	120	2
Clay		120	130	10
Caliche	WB	130	132	2
Clay		132	140	8

RECEIVED
FEB 26 1993
Div. of Water Resources
Ground Water - Las Vegas, NV

Date started 1-23, 19 93
Date completed 1-29, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
12½ Inches From 140 Feet To 0 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 3/4	16.94	.188	0	140

Perforations:
Type perforation Factory Saw cut
Size perforation ⅛ x 3
From 130 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 2-5-93

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627