WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40449
Permit No.
Basin

NOTICE OF INTENT NO. 11575

1. OWNER Jean Woods
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 2 Stagecoach

2. LOCATION NW ¼ SW ¼ Sec. 3 T. 20S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 35-521-18 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	12	12
Calichie		12	14	2
Clay		14	24	16
Calichie		24	26	2
Clay		26	33	7
Callichie		33	35	2
Clay		35	55	20
Calichie		55	56	1
Clay		56	65	9
Callichie	WB	65	67	2
Clay		67	89	22
Calichie	WB	89	91	2
Clay		91	105	14
Calichie	WB	105	107	2
Clay		107	124	17
Callichie	WB	124	126	2
Clay		126	131	5
Calichie	WB	131	133	2
Clay		133	140	7

RECEIVED
JAN 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-21, 1993
Date completed 1-23, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation ⅛x3"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1602
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 1-23-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627