

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **40491**
 Permit No. _____
 Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **10417**

1. OWNER Tony Borrello ADDRESS AT WELL LOCATION Lot 17 Gamebird
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SE 1/4 Sec 35 T 20S N/S R 53 E Nye County
 PERMIT NO. 41-201-22 Parcel No. _____ Subdivision Name Calunda Unit 3
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	10	10
caliche		10	12	2
Clay		12	23	11
caliche		23	26	3
clay		26	42	16
caliche		42	44	2
clay		44	61	17
caliche	WB	61	63	2
clay		63	80	17
caliche	WB	80	82	2
Clay		82	102	20
caliche	WB	102	106	4
Clay		106	116	10
caliche	WB	116	118	2
Clay		118	127	9
caliche	WB	127	129	2
Clay		129	140	11

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

 Perforations:
 Type perforation Factory Saw Cut
 Size perforation 1 3/4 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 DEC 08 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 11-23, 1992
 Date completed 11-28, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 59 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 7 & Box 80358 Contractor
Pahrump NV 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dunn
 By driller performing actual drilling on site or contractor
 Date 11-30-92

