



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10332

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Robert Passafiuma ADDRESS AT WELL LOCATION Bonnie St  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NE 1/4 Sec. 11 T. 21S N/S R. 53 E Nye County \_\_\_\_\_  
 PERMIT NO. 44-302-12 Issued by Water Resources Parcel No. \_\_\_\_\_  
Soyeelya Estates Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Caliche		5	8	3
Clay		8	23	15
Caliche		23	27	4
Clay		27	56	19
Caliche		56	59	3
Clay		59	65	6
Caliche	WB	65	67	2
Clay		67	79	12
Caliche	WB	79	84	5
Clay		84	97	13
Caliche	WB	97	102	5
Clay		102	115	13
Caliche	WB	115	119	4
Clay		119	140	21

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>1.88</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Saw Cut  
 Size perforation 1/2 x 3/8  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED  
 DEC 02 1992  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 11-2, 1992  
 Date completed 11-6, 1992

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
 Address HER 78 Box 80358 Contractor  
Pahrump NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 11-20-92