

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 40520
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 10412

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Joe Pelliccioni ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ Msanse Rd.
 2. LOCATION SE 1/4 SE 1/4 Sec. 4 T. 21-S. N/S R. 54 E. Nye County
 PERMIT NO. _____ 45-031-08 Christensen Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown clay		4	16	12
Brown clay/gravel		16	19	3
Brown clay		19	42	23
Brown clay/gravel	X	42	92	50
Gravel/Fine sand		92	112	20
Brown clay/gravel	X	112	125	13
Brown clay		125	140	15

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4 in. width 8 in. long
 From 100 feet to 140 feet
 From _____ feet to _____ feet

RECEIVED
 FEB 03 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started January 20, 1993
 Date completed January 23, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>4</u>	<u>1/4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jim Pike Well Drilling Contractor
 Address P. O. Box 56 Contractor
Pahrump, Nevada 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
 Signed Jim Pike
 By driller performing actual drilling on site or contractor
 Date January 25, 1993