

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.34

Log No. 40524
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 10439

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Bob Reger
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION Lot 13
HAWKINS
 2. LOCATION SE 1/4 NW 1/4 Sec. 18 T. 21S N/S R. S4 E Nye County
 PERMIT NO. _____ Parcel No. 45-229-05 Subdivision Name Chambliss Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	7	7
Caliche		7	14	7
Clay		14	28	14
Caliche		28	31	3
Clay		31	56	25
Caliche		56	60	4
Clay		60	74	14
Caliche	WB	74	77	3
Clay		77	94	17
Caliche	WB	94	101	7
Clay		101	115	14
Caliche	WB	115	119	4
Clay		119	131	12
Caliche	WB	131	136	5
Clay		136	140	4

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.44</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Sawcut
 Size perforation 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 DEC 02 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 11-16, 1992
 Date completed 11-22, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 58 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HEB 78 Box 80358 Contractor
Phonix NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 11-20-92