WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40531
Permit No.
Basin 162

NOTICE OF INTENT NO. 10360

1. OWNER JIM GREEN
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT-315 SAVOY ST. PAHRUMP NV

2. LOCATION SW ¼ NW ¼ Sec. 20 T. 21 S N/S R. 54 E NVE County
PERMIT NO. (Issued by Water Resources) 45-284-21 (Parcel No.) GREEN SADDLE RANCH (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	12	12
CALICHIE		12	15	3
CLAY		15	38	23
CALICHIE		38	41	3
CLAY		41	54	13
CALICHIE		54	57	3
CLAY		57	64	7
CALICHIE	W.B	64	66	2
CLAY		66	82	16
CALICHIE	W.B	82	87	5
CLAY		87	97	10
CALICHIE	W.B	97	99	2
CLAY		99	118	19
CALICHIE	W.B	118	121	3
CLAY		121	134	13
CALICHIE	W.B	134	137	3
CLAY		137	140	3

RECEIVED
JAN 05 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-16, 1992
Date completed 12-21, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ¼ INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 12-21-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627