WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40542
Permit No.
Basin 163

NOTICE OF INTENT NO.

1. OWNER Guy Bergstrom
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 16 T. 24 S N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) 580-120-049 (Parcel No.) Sandy Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Gravel		5	70	65
Cemented Gravel		70	80	10
Brown Clay & Gravel	x	80	90	10
Gravel		90	115	25
Brown Clay	x	115	125	10
Reddish Brown Clay		125	130	5
Brown Clay & Gravel		130	165	35
Grey Clay & Gravel	x	165	180	15
Reddish Brown Clay		180	200	20

RECEIVED
JAN 22 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started August 25, 19 92
Date completed September 3, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	200 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18 lbs.	.188	0	200

Perforations:
Type perforation Torch Cut
Size perforation 1/8" x 12"
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed (By driller performing actual drilling on site or contractor)
Date 1-16-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627