

OFFICE USE ONLY
Log No. 40544
Permit No. 58384
Basin. 163

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10348

Sandy Valley Community Church
OWNER WALTER MARTIN

MAILING ADDRESS HCR 31 Box 212 ADDRESS AT WELL LOCATION JADE AV. + MOHAWK ST. SANDY VALLEY
JEAN NEVADA 89019

2. LOCATION SW 1/4 NE 1/4 Sec 6 T 25 N/S R 57 E CLARK County
PERMIT NO. 58384 Issued by Water Resources Parcel No. 590-920-022 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	6	6
CLAY		6	36	30
CALICHE		36	39	3
CLAY		39	51	12
CALICHE	W.B.	51	55	4
CLAY		55	67	12
CALICHE	W.B.	67	70	3
CLAY		70	91	21
CALICHE	W.B.	91	101	10
CLAY		101	109	8
CALICHE	W.B.	109	115	6
CLAY		115	120	5

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet
HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 120 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>120</u>

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 8 INCH BY 3 INCH
From 120 feet to 100 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 120 feet to 50 feet

RECEIVED
JAN 05 1993
Div. of Water Resources
Branch Office Las Vegas, NV

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality _____

Date started 12-9, 1992
Date completed 12-11, 1992

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING Contractor
Address HCR 78 BOX 80358 Contractor
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Annie Brown
By driller performing actual drilling on site or contractor
Date 12-11-92

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	