WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40556
Permit No.
Basin 70

NOTICE OF INTENT NO. 22387

1. OWNER Victor & Paulin Lambert
MAILING ADDRESS 3700 W. Lambert Dr.
Winnemucca, Nevada 89445

ADDRESS AT WELL LOCATION
No. #s. Lambert Road

2. LOCATION S.E. ¼ N.W. ¼ Sec. 21 T. 37 N. N/S R. 38 E. Humboldt County
PERMIT NO. A.P.N. 06-516-01 (Issued by Water Resources) | Block D Lot # 1 (Parcel No.) | 5 mile Acres (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[x] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Brown		0	2	2
Clay Brown		2	5	3
Gravel Brown		5	77	72
Sand & gravel brown	23	77	100	23

'93 FEB -8 P2:36
STATE ENGINEER'S OFFICE

Date started Dec. 21, 19 92
Date completed Jan. 7, 19 93

7. WELL TEST DATA
TEST METHOD: [x] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	10	2½

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	100 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	14	.188	0	100

Perforations:
Type perforation torch
Size perforation 1/8" by 5"
From 78 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [x] Pumped [ ] Poured
Seal Type: [x] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name T. & R. Drilling (Contractor)
Address P.O. Box 1982 (Contractor)
Winnemucca, Nevada 89446

Nevada contractor's license number issued by the State Contractor's Board 017721

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190

Signed Thomas [signature] (By driller performing actual drilling on site or contractor)

Date Feb. 5, 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627