

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 21209

1. OWNER N. D. O. T. ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS Maine Ave St. Lovelock NV  
 2. LOCATION NE 1/4 SW 1/4 Sec 27 T. 26 S R. 31 E Pershing County  
 PERMIT NO MW 635 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG MW-4

Material	Water Strata	From	To	Thick-ness
<u>Clayey silt</u>	<u>No</u>	<u>0'</u>	<u>10'</u>	<u>10'</u>
<u>Sandy silt</u>	<u>20.5</u>	<u>10'</u>	<u>25'</u>	<u>15'</u>

*Augered & Abandoned by excavation May 26, 1993*

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cascd. 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>Sch. 40</u>	<u>N/C</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation Factory slot  
 Size perforation .020  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 1.0 feet to 2.0 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Depth of Seal 8  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 8 feet to 25 feet

9. WATER LEVEL  
 Static water level 20.5 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality N/A

Date started 2/2 1993  
 Date completed 2/2 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
			<u>N/A</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Andrew Drilling Contractor  
 Address 1635 Bedford RD, Reno NV, 89509 Contractor  
 Nevada contractor's license number 34525 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2/5/93