WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40561
Permit No.
Basin 87

NOTICE OF INTENT NO. 19676

1. ~~OWNER~~ Consultant: Converse Environmental Cons. SW Inc.
MAILING ADDRESS 4670 So. Polaris Ave.
Las Vegas, NV 89103-5615

Client:
ADDRESS AT WELL LOCATION Flamingo Hotel
225 North Sierra Street
Reno, NV

2. LOCATION SW ¼ NE ¼ Sec. 11 T 19N N/S R 19 E Washoe County
PERMIT NO. M/O 517 (Issued by Water Resources) Parcel No. Downtown Reno (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphaltic Concrete		0	3"	3"
Gravelly sand, w/cobbles & boulders, med dense brown, moist.		3"	10'	9'7"
Silty sand, med. dense brown, moist		10	14	4
Gravelley sand, w/cobbles, med dense, brown moist		14	25	11
Gravelly sand, med. dense, gray, moist		25	39	14
Wet @	X	27		
Some intermittent layer of Silty Clay from		31	38	
Color change to brown At		37		
Silty sand, w/gravel & cobbles, med. dense, brown		39	45	6
Medium dense, saturated @		42		

Date started ..., 19..
Date completed ..., 19..

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

COPY

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 5/16 Inches	0 Feet	45 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		sch 40	0	45
End cap				
Locking cap				

Perforations:
Type perforation factory sawed slot
Size perforation .020 x 1.5 x 6 row
From 15 feet to 45 feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 2' bentonite & 11'
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Placement Method: [X] Pumped [ ] Poured
Gravel Packed: [X] Yes [ ] No #3 Sand/Lonestar
From 13 feet to 45 feet

9. WATER LEVEL
Static water level 27 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature not/k °F Quality not/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370
Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date February 8, 1993

STATE ENGINEERS OFF
93 FEB -9 P2:47

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627