

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11879

1. OWNER Custom Office Supply ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 250 East Glendale Ave
Sparks NV
 2. LOCATION SW 1/4 SE 1/4 Sec 9 T. 12 S. R. 20 E Clark County
 PERMIT NO. 1010 615 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Case

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Dark Brown Clay No</u>		<u>0</u>	<u>10'</u>	<u>10'</u>
<u>Clayey Cobbles No</u>		<u>10'</u>	<u>23'</u>	<u>13'</u>
<u>Sandy Clayey Cobbles No</u>		<u>23'</u>	<u>30'</u>	<u>7'</u>
<u>Sandy Cobbles Yes</u>	<u>31.5</u>	<u>30'</u>	<u>35'</u>	<u>5'</u>

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 35 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>Sch. 40</u>	<u>100</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation Factory slot
 Size perforation 1020
 From _____ feet to _____ feet
 From 10 feet to 35 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 8 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 8 feet to 35 feet

9. WATER LEVEL
 Static water level 31.5 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Dillman Contractor
 Address 1635 Delwood Rd
RENO NV 89509
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By Driller performing actual drilling on site or contractor
 Date 11/25/93

Date started 11/16 1992
 Date completed 11/16 1992

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
	<u>N/A</u>		

'93 FEB 10 10:17
 STATE ENGINEERS OFFICE