WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40578
Permit No.
Basin 90

NOTICE OF INTENT NO. 21216

1. OWNER Mario Isola Nev. Idn property Inc.
MAILING ADDRESS 5270 Neil Rd. Suite 203 Reno NV
ADDRESS AT WELL LOCATION Whispering Pines 1820 Highway 50 Glenbrook NV

2. LOCATION NE ¼ SW ¼ Sec. 15 T. 14 N/S R. 18 E. Douglas County
PERMIT NO. M/O 6021A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG MW-6

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand Brn | 15.8 | 0 | 30' | 30' |

'93 FEB 10 A10:13
STATE ENGINEERS OFFICE

Date started 12/8, 1992
Date completed 12/8, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 7 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | | Sch. 40 | 0 | 30 |

Perforations:
Type perforation factory slot
Size perforation .020
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 11'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 11 feet to 30 feet

9. WATER LEVEL
Static water level 15.8 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andrew Drilling (Contractor)
Address 1635 Belford RD (Contractor)
RENO NEV, 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 1/25/93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627