

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21656

1. OWNER BOOMTOWN HOTEL & CASINO ADDRESS AT WELL LOCATION Garson Rd & 2200 I-80 West  
 MAILING ADDRESS P.O. BOX 399 Verdi, NV 89439  
 VERDI, NV 89439

2. LOCATION NE 1/4 SW 1/4 Sec. 16 T. 19N N/S R. 18 E Washoe County  
 PERMIT NO. 36513 Boomtown Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL ABANDONMENT:				
Total depth <u>119.37 feet.</u>				
Static water level at <u>81 feet.</u>				
EQUIPMENT USED:				
<u>T660 Schramm Drill with 3 man crew</u>				
<u>Holt down hole perforator</u>				
<u>Walnut Grove grout pump &amp; mixer</u>				
<u>120 feet of 1/4" tremie pipe</u>				
MATERIALS:				
<u>143 sacks II Portlan Cement</u>				
<u>3.3 sacks Bentonite powder</u>				
<u>DECEMBER 1, 1992</u>				
<u>Casing could not be pulled</u>				
<u>Casing perforated from 115 feet to 40 feet.</u>				
<u>Casing above 40 feet cemented. Attempts to</u>				
<u>perforate this area met with tool refusal.</u>				
<u>Day one 65 sacks cement pumped through tremie.</u>				
<u>Fluid level did not rise.</u>				
<u>DECEMBER 2, 1992</u>				
<u>Day two. Pump 78 sacks through tremie to</u>				
<u>bring cement to surface.</u>				
<u>Steel cap welded on top of casing.</u>				
<u>Check cement on December 5, 1992. Level at 5 feet.</u>				

8. ORIGINAL WELL CONSTRUCTION  
 Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>1</u>	<u>125</u>

Perforations:  
 Type perforation factory  
 Size perforation ?

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped ?  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 125 feet

9. WATER LEVEL  
 Static water level 81 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 12-1-92, 19\_\_\_\_  
 Date completed 12-2-92, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number 908 issued by the Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date February 2, 1993

RECEIVED STATE ENGINEERING  
 FEB 5 1993