

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21217

1. OWNER Village Market ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 2900 Nevada Ave
Silver Springs NV
 2. LOCATION SW 1/4 SW 1/4 Sec 19 T 18 R 25 E Lyon County
 PERMIT NO. 1710 555 B Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG 1710-4

Material	Water Strata	From	To	Thickness
Gravel Base	No	0'	1'	1'
Clayey silt	No	1'	9'	8'
Silty clay	No	9'	18'	9'
Hard silt	No	18'	25'	7'
Sand	No	25'	35'	10'
Gravelly sand	No	35'	37'	2'
Sand	Yes 39	37'	49'	12'
Clay	Yes	49'	50'	1'

93 FEB 10 AM 10:17 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 50 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 50 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>Sch. 40</u>	<u>PVC</u>	<u>0</u>	<u>50</u>

Perforations:
 Type perforation Factory slot
 Size perforation .020
 From _____ feet to _____ feet
 From 35 feet to 50 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 33 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 33 feet to 50 feet

9. WATER LEVEL
 Static water level 39 feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Anthony Drilling
 Address 1635 Belford RD, Reno NV 89509
 Nevada contractor's license number 34525 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1028
 Signed Anthony Drilling
 By driller performing actual drilling on site or contractor
 Date 1/25/93

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		

 Date started 12/10 1992
 Date completed 12/10 1992