WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40595
Permit No.
Basin 108

NOTICE OF INTENT NO. 21213

1. OWNER Lyon County School District
MAILING ADDRESS Yerington NV
ADDRESS AT WELL LOCATION Lyon County School Bus Garage Yerington NV

2. LOCATION NW 1/4 1/4 Sec. 14 T. 13 N/S R. 25 E. Lyon County
PERMIT NO. MO 618A-3W (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG VBS-18

Material	Water Strata	From	To	Thickness
Silty Sand	Yes 14.5	0	15'	15'
Sand	Yes	15'	30'	15'

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Sch. 40	PVC	0	30

Perforations:
Type perforation Factory Slot
Size perforation .020
From feet to feet
From 7 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 5 feet to 30 feet

9. WATER LEVEL
Static water level 14.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anderson Drilling (Contractor)
Address 1635 Bellevue RD. (Contractor)
RENO NEV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed (By driller performing actual drilling on site or contractor)
Date 1/25/93

Date started 1/14, 1993
Date completed 1/14, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

93 FEB 10 AM 10:16
STATE ENGINEER'S OFFICE

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627