

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21205

1. OWNER Wells Cargo ADDRESS AT WELL LOCATION Wells Cargo
 MAILING ADDRESS 1775 East 4th St Freight Terminal
Reno NV 89512 Luning NV
 2. LOCATION New $\frac{1}{4}$ SE $\frac{1}{4}$ Sec 34 T. 8 S. R. 34 E. Mineral County
 PERMIT NO. MO 599 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE Vapor
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Vapor

6. LITHOLOGIC LOG WCUZ-4

Material	Water Strata	From	To	Thick-ness
<u>Silty Sand</u>	<u>No</u>	<u>0</u>	<u>15'</u>	<u>15'</u>
<u>Silty Sand</u>	<u>No</u>	<u>15'</u>	<u>60'</u>	<u>45'</u>

'93 FEB 10 AIO 16
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Depth Drilled 60 Feet Depth Cased 60 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 60 Feet
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>Sch. 40</u>	<u>PVC</u>	<u>0</u>	<u>60</u>

Perforations:
 Type perforation Factory Slot
 Size perforation .020
 From 10 feet to 60 feet
 From 10 feet to 60 feet
 From 10 feet to 60 feet
 From 10 feet to 60 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 8 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 8 feet to 60 feet

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

Date started 10/28 1992
 Date completed 10/28 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
			<u>N/A</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Dilling Contractor
 Address 1635 Bedford Rd Reno NV 89509 Contractor
 Nevada contractor's license number 34525 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed Andrew Dilling
 By driller performing actual drilling on site or contractor
 Date 11/25/93