

OFFICE USE ONLY
 Log No. 10622
 Permit No. 83
 Basin 83

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INSENT NO. 14037
All - Lite

PRINT OR TYPE ONLY

1. OWNER Storey County Properties ADDRESS AT WELL LOCATION Aggregate, Lockwood Canyon
 MAILING ADDRESS 1580 Twin Oaks Road
Reno, NV 89511

2. LOCATION NW 1/4 NW 1/4 Sec. 35 T. 19 N. R. 21 E. Storey County

PERMIT NO. 56922-T Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium Fill (Brown)		0	20	20
Light gray to white clay	x	20	30	10
Gray Clay	x	30	70	40
Gray Volcanics		70	100	30
Light Brown Volcanics		100	110	10
Brown & Gray Volcanics		110	120	10
Dark Gray Volcanics	x	120	160	40
Light Gray Volcanics		160	170	10
Brown Gray Volcanics		170	180	10
Light Gray Volcanics		180	200	20
Dark Gray Volcanics		200	220	20
Brown Volcanics		220	230	10
Gray Volcanics	x	230	240	10
Hard Dark Volcanics		240	270	30
Light Gray Volcanics		270	360	90
Dark Gray Volcanics	x	360	400	40

93 MAR -8 P12:36
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter _____ inches Total depth 400 feet
 _____ 16 inches 0 - 24
 _____ 12 inches 24 - 400

Casing record 33.38 _____ 250-12-3/4
 Weight per foot 16.94 _____ 188-8 Thickness _____

Diameter	From	To
<u>12 3/4</u> inches	<u>0</u> feet	<u>24</u> feet
<u>8</u> inches	<u>+2</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 100' feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 400 feet

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 8 rows
 From 120 feet to 320 feet
 From 340 feet to 380 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4 - 16, 1992
 Date completed 4 - 30, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Submersible</u>	<u>250</u>	<u>180</u>	<u>4</u>
<u>40 HRP</u>			
<u>Set @ 336'</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 20' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 63 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Contractor
 Address 557 Ely Ave, Ely, NV 89301
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada contractor's driller's number issued by the Division of Water Resources 641
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3-01-93