WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40623
Permit No.
Basin 97

NOTICE OF INTENT NO. 20004

1. ~~OWNER~~ Consultant: Simon Hydro-Search
MAILING ADDRESS 5250 S.Virginia St.
Reno, NV. 89502

Client: Jean Hansen
ADDRESS AT WELL LOCATION Reno Rents 1920 Glendale Ave
Sparks, NV.

2. LOCATION SW ¼ NW ¼ Sec. 8 T 19N N/S R 20 E Washoe County
PERMIT NO. M/O 525 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other TUPEX

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill | | 0 | 1 | 1 |
| Gravelly Clay | | 1 | 3 | 2 |
| Gravelly boulder Sand | | 3 | 7 | 4 |
| Sandy Gravel | | 7 | 13 | 6 |
| Boulder Sand | | 13 | 16 | 3 |
| Sand | | 16 | 18 | 2 |
| Sand Boulders | | 18 | 24 | 6 |
| Sand | | 24 | 26 | 2 |
| Sandy Boulders | | 26 | 30 | 4 |
| Sandy Boulders w/ silt | X | 30 | 38 | 8 |
| Sandy Boulders 15% sand | X | 38 | 42 | 4 |
| Gravelly Sand | X | 42 | 48.5 | 6.5 |
| Silty Sand | X | 48.5 | 49 | .5 |

'93 MAR 17 P1:05
STATE ENGINEER

Date started October 7, 1992, 19
Date completed October 8, 1992, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| NO TEST | | | |

8. WELL CONSTRUCTION
Depth Drilled 49 Feet Depth Cased 48.5 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 9 5/16 Inches | 0 Feet | 49 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" PVC | | SCH 40 | 0 | 18.5 |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine Slot
Size perforation 0.040
From 18.5 feet to 48.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 12.5
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Bentonite Seal@ 12.5-15.5
Gravel Packed: [X] Yes [ ] No #3 Lonestar Sand
From 15.5 feet to 48.5 feet

9. WATER LEVEL
Static water level 31 feet below land surface
Artesian flow Not Known G.P.M. P.S.I.
Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 15, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627