

OFFICE USE ONLY
 Log No. 40637
 Permit No. 89
 Basin. 89

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 22422

1. OWNER Leon Lyman ADDRESS AT WELL LOCATION 4090 Blue wing New Washo
 MAILING ADDRESS 13501 GUFFY DR. New Washo City
 2. LOCATION SW 1/4 SE 1/4 Sec. 32 T. 17 N. S. R. 20 E Washo County
 PERMIT NO. 22422 Issued by Water Resources Parcel No. 050-417-12 Subdivision Name New Washo

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	25'	25'
Firm sandstone		25	40'	15'
Brown Sandy clay		40	55'	15'
3/8" gravel's sand		55	65'	10'
soft gummy Brown clay		65	80'	15'
Brown clay with small 3/8" gravel's		80	105'	25'
coarse 1/4" gravel's		105	110'	5'
Firm Brown clay		110'	155'	45'
D.G. sand's coarse water	X	155'	175'	20'
gray clay		175'	180'	5'
Hard Broken D.G.	X	180	200'	20'
T.I.D. 200'				
Static, 85'				

8. WELL CONSTRUCTION
 Depth Drilled 200' Feet Depth Cased 200' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1 1/4 Inches 0 Feet 60' Feet
9 7/8 Inches 60' Feet 200' Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>200'</u>

Perforations:
 Type perforation mill slot
 Size perforation 3 1/2 X 3 3/8
 From 130' feet to _____ feet
 From _____ feet to 200' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60' feet to 200' feet

9. WATER LEVEL
 Static water level 85' feet below land surface
 Artesian flow _____ G.P.M. 15 P.S.I.
 Water temperature Cold! °F Quality Good

Date started 2-19 1993
 Date completed 2-22 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>15+</u>	<u>120'</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AT H pump co. Contractor
 Address 5551 Hy 50 E #3 Carson City NV, 89701 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1674
 Signed Joe Butts By driller performing actual drilling on site or contractor
 Date 2-23-93