

OFFICE USE ONLY
 Log No. 40643
 Permit No. 93
 Basin 93
 NOTICE OF INTENT NO. 21679

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Jim Stewart ADDRESS AT WELL LOCATION 15255 Elkhorn
1128 La Via Way Reno, NV
 Sparks NV
 2. LOCATION NW 1/4 SW 1/4 Sec. 23 T. 22 N. R. 19 E. Washoe County
 PERMIT NO. N/A 079-470-61 Red Rock Estates #1 (E) part 1
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sandy Clay		0	77	77
Gray Clay		77	141	64
Gray Sandy Clay		141	160	19
Brown Sandy Clay	x	160	185	25
Brown DG	xx	185	206	21
see also log # 405348				
93 MAR 10 AM 9:55				
STATE ENGINEER OFFICE				

8. WELL CONSTRUCTION
 Depth Drilled 206 Feet Depth Cased 206 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 7/8 Inches 0 Feet 206 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	-1	206

Perforations:
 Type perforation Mill Slot
 Size perforation 1/8" x 3"
 From 166 feet to 206 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60'+ Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 60 feet to 206 feet

9. WATER LEVEL
 Static water level 47 feet below land surface
 Artesian flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality good

Date started 2-13-93, 19_____
 Date completed 2-23-93, 19_____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	50	195	4

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EMDLCO Drilling
 Contractor
 Address P.O. Box 8056
 Contractor
Reno, NV 89507
 Nevada contractor's license number issued by the State Contractor's Board 32166-C23
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 3-7-93