

OFFICE USE ONLY
 Log No. 40655
 Permit No. 101
 Basin. 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22508

1. OWNER Sharon Ream ADDRESS AT WELL LOCATION 2121 Coleman Road
 MAILING ADDRESS 1160 Roberson Lane Fallon, NV 89406
 LOCATION SE 1/4 NE 1/4 Sec 26 T 19 N/S R 28 E Churchill County
 PERMIT NO. 08-391-12 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---------------------------|--------------|------|-----|-----------|
| Sand | | 0 | 18 | 18 |
| Brown Clay | | 18 | 25 | 7 |
| Brown Fine Sand | | 25 | 29 | 4 |
| Green Clay | | 29 | 30 | 1 |
| Black & Green Coarse Sand | | 30 | 33 | 3 |
| Brown Coarse Sand | | 33 | 38 | 5 |
| Brown Fine Sand | | 38 | 39 | 1 |
| Fine Green Sand | | 39 | 55 | 16 |
| Black & Green Coarse Sand | | 55 | 64 | 9 |
| Fine Green Sand | | 64 | 81 | 17 |
| Black & Green Coarse Sand | | 81 | 84 | 3 |
| Brown Coarse Sand | | 84 | 88 | 4 |
| Brown Clay | | 88 | 90 | 2 |
| Brown Coarse Sand | X | 90 | 105 | 15 |

8. WELL CONSTRUCTION
 Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 105 Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6-5/8 | 12.92 | .188 | 0 | 105 |

Perforations:
 Type perforation Mill Cut
 Size perforation 1 7/8"
 From 102 feet to 105 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 95 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 95 feet to 105 feet

Date started February 25, 1993
 Date completed February 25, 1993

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 11' 3" feet below land surface
 Artesian flow cool G.P.M. unknown P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Douglas Parsons
 By driller performing actual drilling on site or contractor
 Date March 8, 1993