

OFFICE USE ONLY  
 Log No. 40062  
 Permit No. \_\_\_\_\_  
 Basin. 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22599

1. OWNER Wendy Greenwell ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 583 S. Laverene 1111 Ernst Dr.  
Fallon, NV 89406 Fallon, NV 89406  
 2. LOCATION SW 1/4 SW 1/4 Sec 32 T 19 N 29 E Churchill County  
 PERMIT NO. 10-494-13 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Brown Clay		8	13	5
Brown Coarse Sand		13	15	2
Brown Fine Sand		15	30	15
Fine Green Sand		30	36	6
Black Clay		36	38	2
Green Sandy Clay		38	43	5
Black Clay		43	58	15
Fine Gray Sand		58	69	11
Black & Green Coarse Sand		69	74	5
Fine Gray Sand		74	83	9
Black & Green Coarse Sand		83	96	13
Green & Brown Coarse Sand		96	101	5
Fine Brown Sand		101	109	8
Brown Clay		109	120	11
Fine Brown Sand		120	123	3
Brown Coarse Sand	X	123	130	7

8. WELL CONSTRUCTION  
 Depth Drilled 130 Feet Depth Cased 130 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 130 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	130

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8"  
 From 126 feet to 129 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 130 feet

9. WATER LEVEL  
 Static water level 12' 9" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Doug Parsons  
 By driller performing actual drilling on site or contractor  
 Date March 8, 1993

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started February 24, 19 93  
 Date completed February 24, 19 93