WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40664
Permit No.
Basin 8-103

NOTICE OF INTENT NO.

1. OWNER Robert And Lorna Little
MAILING ADDRESS 170 Julie Way Dayton, NV. 89403
ADDRESS AT WELL LOCATION 170 Julie Way Dayton NV. 89403

2. LOCATION NW ¼ SE ¼ Sec. 20 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) 03-316-21 (Parcel No.) Mark Twain (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [X] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders and Dirt.		0	38	38
Boulders + Cemented Sand and Gravel		38	90	52
Brown Clay		90	93	3
Broken Brown Shale with Brown Clay Mixed		93	219	126
Red Clay		219	223	4
Black Hard Shale		223	276	53
Broken Black And White Hard Shale Quartz Seams Mixed.	✓	276	300	24

Date started FEB 2, 1993
Date completed FEB 6, 1993

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	300'	5 Hrs.

Air Developed

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 301' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	0 Feet	60' Feet
8 3/4 Inches	60 Feet	300' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	+1'	300'

Perforations:
Type perforation Air Star Perforator
Size perforation 3/16 x 1 5 Rows
From 240' feet to 300' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 300' feet

9. WATER LEVEL
Static water level 200' feet below land surface
Artesian flow NA G.P.M. 35 P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address P.O. Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathan L. Leach Sr. (By driller performing actual drilling on site or contractor)
Date 2/20/93

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627