

OFFICE USE ONLY
 Log No. 40069
 Permit No. 105
 Basin. 105

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 20840

PRINT OR TYPE ONLY

1. OWNER MIKE MCCORMICK ADDRESS AT WELL LOCATION 2750 Goodrite rd, Minden NV
 MAILING ADDRESS Box 2914 MINDEN NV
 2. LOCATION NW 1/4 NE 1/4 Sec. 35 T. 14 N/S R. 20 F. Douglas County
 PERMIT NO. 21-250-36 Issued by Water Resources Parcel No. N/A Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|-----|------------|
| CLAY & SAND | | 0 | 20 | |
| CLAY SAND & GRAVEL | | 20 | 25 | |
| CLAY & SAND | | 25 | 70 | |
| CLAY SAND & GRAVEL | | 70 | 80 | |
| CLAY & SAND | | 80 | 140 | |
| SAND | | 140 | 160 | |
| CLAY & SAND | | 160 | 170 | |
| SAND | X | 170 | 240 | |
| CLAY (BLUE) | | 240 | 255 | |
| CLAY & SAND | | 255 | 265 | |
| CLAY | | 265 | 285 | |
| CLAY & GRAVEL | | 285 | 300 | |

8. WELL CONSTRUCTION
 Diameter 9 7/8 inches Total depth 300 feet
 Casing record 6 5/8" x 188" x 300'
 Weight per foot _____ Thickness _____

| Diameter | From | To |
|-----------------|---------------|-----------------|
| <u>6</u> inches | <u>0</u> feet | <u>300</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type GRAVEL
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 300 feet to 50 feet
 Perforations:
 Type perforation Factory & hand cut
 Size perforation
 From 300 feet to 280 feet
 From 230 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 2-27 1993
 Date completed 3-2 1993

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-----------|--------|-----------|------------------|
| <u>50</u> | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 182 feet below land surface
 Flow 1.5 G.P.M. P.S.I.
 Water temperature Cold °F Quality N/A

BAILER TEST
 G.P.M. 15+ Draw down _____ feet 2 1/2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kawdrack Drilling Inc. Contractor
 Address 2668 Fuller Minden NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board #021268
 Nevada contractor's driller's number issued by the Division of Water Resources #1380
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
 Signed Michael Collier
 By driller performing actual drilling on site or contractor
 Date 3-3-93